

I.C.R. W.U.A. Monthly Operator Notes
May 24, 2016

Molly Way was flushed twice and the fire pumps exercised.

The easement road was checked twice to insure no leaks or issues with our line

Replaced high use meter at TRR guard house

Ordered 2 inch meter rebuild kits and will begin meter change outs when kits arrive

24 hr. well test on ICR well #2 was completed

We have had a few call on high usage, and a call about high pressure

We had Enviro-Tech check the electrical panel at the water building, everything checked out fine

(1) Non-routine meter install (W.C.)

The 2015 CCR is complete and I will be sending it to ADEQ

Meter reads went well this month the new system seems to be working good

Monthly samples were collected and delivered to the lab. (No issues)

All equipment is working properly at this time with the exception of the Molly Way program issue

